

Message

From: Piplic, Devlin [piplicd@monroe.wednet.edu]
Sent: 3/22/2017 8:08:08 PM
To: Moore, Kendall [moore.kendall@epa.gov]
CC: Jeff Ketchel [jketchel@snohd.org]; Amanda Zych [azych@snohd.org]; Kevin Plemel [kplemel@snohd.org]; Mullin, Michelle [Mullin.Michelle@epa.gov]; Ramanauskas, Peter [ramanauskas.peter@epa.gov]; John Mannix [mannixj@monroe.wednet.edu]; Fredrika Smith [smithf@monroe.wednet.edu]; Joanie Gilbert [gilbertj@monroe.wednet.edu]
Subject: Re: Electrical Rooms at Sky Valley Education Center
Attachments: SVEC Electrical Inventory.xlsx

Kendall,

Which documents are you having problems accessing? I have included the inventory sheet, but the pictures will be too large to send via email.

Devlin

On Wed, Mar 22, 2017 at 1:00 PM, Moore, Kendall <moore.kendall@epa.gov> wrote:

I can not access the document. Can you send it in a different format.

From: Piplic, Devlin <piplicd@monroe.wednet.edu>
Sent: Wednesday, March 22, 2017 2:53:08 PM
To: Jeff Ketchel; Amanda Zych; Kevin Plemel; Mullin, Michelle; Ramanauskas, Peter; Moore, Kendall; John Mannix; Fredrika Smith; Joanie Gilbert
Subject: Electrical Rooms at Sky Valley Education Center

Good Afternoon,

I am following up on our discussion yesterday. I have created a shared drive and sent invitations out to everyone. As requested, the following items have been completed:

- Signs have been posted at the entrance of all electrical rooms. Signs specific to PCBs have been posted in the space. I have also had a conversation about potential PCBs in the space with the custodial staff. There is a file in the shared drive that shows a picture of all signs posted. They locks have also been changed and only the custodial staff will have access.
- There are files with photo graphs of all electrical equipment. I took pictures of the equipment as well as the ID tags.
- There is a spreadsheet that has a inventory list with critical information about the electronic equipment.
- All electrical rooms have candescent light fixtures with the exception of the small gym electrical room. There are 3 light fixtures in this space containing ballasts. These ballasts are currently electronic ballasts. They were magnetic ballast that had labels indicating no PCBs. I took pictures of the fixtures and ballasts. They are in the photo folder in the file.

I believe I have provided all the information requested. Please let me know if you need any additional information. Please let me know if I should add anyone to that shared drive for access that I may have overlooked.

--

Devlin Piplic

Director of Facilities
200 East Fremont
Monroe, WA 98272
Office: 360.804.2679



Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal. If you have received this e-mail in error, please immediately notify us by return e-mail. All email to and from this domain is archived as a public record in compliance with federal and state requirements. As such they may be both discoverable in a legal action and available through a public records request.

--

Devlin Piplic

Director of Facilities
200 East Fremont
Monroe, WA 98272
Office: 360.804.2679



Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal. If you have received this e-mail in error, please immediately notify us by return e-mail. All email to and from this domain is archived as a public record in compliance with federal and state requirements. As such they may be both discoverable in a legal action and available through a public records request.